

P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

FALL MAINTENANCE MANUAL

PARISH _____

ADDRESS ______

2011

Page **1** of **13**



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

FALL MAINTENANCE

HEAT PUMP MAINTENANCE

INSPECT ALL HEAT EXCHANGERS INSPECT ALL HEATING COIL TUBES CHECK HEATING COIL MOUNTINGS AND TIGHTEN TO SPECIFICATION INSPECT COIL CASING FOR RUST AND PAINT AS NEEDED CHECK ALL CONTROL VALVES FOR PROPER OPERATION INSPECT. ADJUST. CALIBRATE AND CLEAN ALL TEMPERATURE CONTROLS MAKE ALL FILTER CHANGES AS PER SPECIFICATION

HEATING MAINTENANCE

CLEAN OIL STRAINERS CHECK DRAFT REGULATORS FOR FREE MOVEMENT INSPECT ALL MOTORIZED DAMPERS FOR ALIGNMENT, BEARING WEAR AND LUBRICATION TEST BOILER WATER FOR PH., HARDNESS AND CORROSIVE COMPOUNDS CHEMICALLY TREAT BOILER WATER AS PER SPECIFICATION PUT BOILER ON LINE AND CHECK ALL CONTROL OPERATIONS CHECK ALL SAFETY VALVES. STEAM PRESSURE CUT OFF HIGH AND LOW CHECK ALL WATER FEEDERS CHECK LOW WATER CUT OFF AND WATER LEVEL CONTROL CHECK HIGH AND LOW TEMPERATURE AQUASTATS CHECK ALL BLOW DOWN OPERATIONS CHECK ALL BLOW DOWN OPERATIONS CHECK ALL BLOW DOWN OPERATIONS CHECK ALL PIPING FOR STEAM OR WATER LEAKS CHECK ALL OPERATING CERTIFICATES



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

FALL MAINTENANCE

SITE MAINTENANCE

CLEAN ALL SEWER AND DRAIN LINES REMOVE ALL FOLIAGE GROWTH NEXT TO BUILDINGS CLEAN AND SERVICE ALL LAWN EQUIPMENT CLEAN AND SERVICE ALL SNOW REMOVAL EQUIPMENT OBTAIN ALL SNOW REMOVAL CONTRACTS

ELECTIUCAL EQUIPMENT MAINTENANCE

REPAIR OR REPLACE ALL SWITCHES AND RECEPTACLES REPLACE ALL FRAYED WIRING REMOVE ALL OVER LOADING EXTENSION WIRING TEST ALL SMOKE AND HEAT DETECTORS AND REPLACE BATTERIES TEST FIRE ALARM SYSTEM TEST EMERGENCY LIGHTING REPLACE ALL BULBS NEEDED AND REPLACE DEFECTIVE FIXTURES

PLUMBING MAINTENANCE

SHUT AND DRAIN ALL EXTERIOR WATER FAUCETS REPLACE ALL LEAKING VALVE GASKETS OR WASHERS REPAIR ALL LEAKING PIPE SYSTEMS

AIR CONDITIONING MAINTENANCE

COVER ALL WINDOW A.C. UNITS FOR WINTER PUMP DOWN SYSTEM MONITOR COMPRESSOR HEATING ELEMENT CIRCUIT TO BE ON LINE DURING WINTER CHECK ALL CONDENSATE PANS AND CLEAN REPLACE ALL WORN BELTS LUBRICATE SYSTEMS AS PER SPECIFICATION CHECK ALL CONTROLS, DAMPERS, AND FILTERS AND REPAIR OR REPLACE AS NEEDED



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A CORNERSTONE OF QUALITY SINCE 1960 P.O. BOX 620 DOVER, NEW JERSEY 07801

PHONE: (973) 442-9492 FAX: (973) 442-1552

FALL MAINTENANCE

BUILDING INTERIOR MAINTENANCE

CLEAN ALL RADIATOR ENCLOSURES AND AIR REGISTERS CLOSE ALL CRAWL SPACE OPENINGS AND BASEMENT WINDOWS USED FOR SUMMER VENTILATION REMOVE AND DISPOSE OF ALL DEBRIS PAINTING AS NEEDED CHECK ALL DOOR PANIC BARS AND LOCKING MECHANISMS REPAIR BROKEN STAIR EDGES AS NEEDED LUBRICATE ALL NEEDED LOCKS AND HINGES

BUILDING EXTERIOR MAINTENANCE

REMOVE. REPAIR AND STORE SUMMER SCREENS REMOVE AND STORE ALL EXTERIOR AWNINGS REPLACE ALL DEFECTIVE WINDOW AND DOOR SEALANT CLEAN AND INSTALL STORM WINDOWS AND WEATHERSTRIPPING REPLACE ALL BROKEN GLASS

ROOF MAINTENANCE

CLEAN ALL DRAINS EXTERIOR AND INTERIOR CLEAN ALL GUTTERS AND LEADERS CLEAN VALLEYS FILL ALL PITCH POCKETS SECURE ALL FLASHING SYSTEMS SECURE ALL ANTENNA SYSTEMS COMPLETE ROOF SURVEY



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A CORNERSTONE OF QUALITY SINCE 1960 P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

FALL PROBLEM HEAT PUMP MAINTENANCE MAJOR MINOR OK **OBSERVATION** DATE **INSPECT AL HEAT EXCHANGERS INSPECT ALL HEATING COIL** TUBES **INSPECT ALL HEATING COIL** MOUNTINGS AND TIGHTEN TO SPECIFICATIONS INSPECT COIL CASING FOR RUST AND PAINT AS NEEDED CHECK ALL CONTROL VALVES FOR **PROPER OPERATION** INSPECT, ADJUCT, CALIBRATE AND CLEAN ALL TEMPERATURE CONTROLS MAKE ALL FILTER CHANGES AS SPECIFICATIONS

DATE

INSPECTOR

2011

'0 \



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A Cornerstone of quality since 1960

P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBLEM

HEATING	MAJOR	MINOR	ОК	OBSERVATION	DATE
CLEAN OIL STRAINERS					
CHECK DRAFT REGULATORS FOR FREE MOVEMENT					
INSPECT ALL MOTORIZED DAMPERS FOR ALIGNMENT, BEARING WEAR AND LUBRICATION					
TEST BOILER WATER FOR PH., HARDNESS AND CORROSSIVE COMPOUNDS					
CHEMICALLY TREAT BOILER WATER AS PER SPECIFICATION					
PUT BOILER ON LINE AND CHECK ALL CONTROL OPERATIONS					
CHECK ALL SAFETY VALVES AND TEST					
CHECK STEAM PRESSURETROL HIGH AND LOW VALVE OPERATION					
CHECK ALL WATER FEEDERS					
CHECK HIGH AND LOW WATER TEMPERATURE AQUASTATS					
COMPLETE BLOW DOWN OPERATION					
CHECK HIGH AND LOW BURNER OPERATION					
CHECK ALL PIPING FOR STEAM LEAKS					
CHECK FOR ALL OPERATING CERTIFICATES					



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBL	EM				
SITE	MAJOR	MINOR	ОК	OBSERVATION	DATE
CLEAN ALL SEWER AND DRAIN LINES AND CATCH BASINS					
REMOVE ALL FOLIAGE GROWTH NEXT TO BUILDINGS FIXTURES					
CLEAN AND SERVICE ALL LAWN EQUIPMENT					
CLEAN AND SERVICE ALL SNOW REMOVAL EQUIPMENT					
OBTAIN ALL SNOW REMOVAL CONTRACTS					



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBLEM

ELECTRICAL EQUIPMENT	MAJOR	MINOR	OK	OBSERVATION	DATE
REPAIR OR REPLACE ALL DEFECTIVE SWITCHES OR RECEPTACLES					
REPLACE ALL FRAYED WIRING					
REMOVE ALL OVERLOADING EXTENSION LINES					
TEST ALL SMOKE AND HEAT					
DETECTORSAND REPLACE ALL BATTERIES					
TEST ALL FIRE ALAM SYSTEMS					
TEST ALL EMERGENCY LIGHTING					
REPLACE ALL BULBS AS NEEDED					
REPLACE ALL DEFECTIVE FIXTURES					



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A CORNERSTONE OF QUALITY SINCE 1960 P.O. BOX 620 DOVER, NEW JERSEY 07801

PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

PROBLEM FALL MAJOR MINOR OK OBSERVATION DATE PLUMBING SHUT AND DRAIN ALL EXTERIOR WATER FAUCETS **REPLACE ALL LEAKING VALVES** GASKETS OR WASHERS REPAIR ALL LEAKING PIPE SYSTEMS REPLACE ALL DEFECTIVE EQUIPMENT



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A CORNERSTONE OF QUALITY SINCE 1960 P.O. BOX 620 DOVER, NEW JERSEY 07801

PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

DATE

INSPECTOR

FALL P	ROBLEM				
AIR CONDITIONING	MAJOR	MINOR	ОК	OBSERVATION	DATE
COVER ALL WINDOW A CONDITIONING UNITS F WINDOW					
PUMP DOWN ALL SYSTE	MS				
MONITOR COMPRESSO HEATING ELEMENT CIRCU BE ON LINE DURING WINT PREVENT COMPRESSOR DA	IT TO ER TO				
CHECK AND CLEAN AL CONDENSATE PANS AND D					
PAINT CONDENSATE PAN NEEDED	S AS				
REPLACE ALL WORN BEI	TS				
LUBRICATE SYSTEM AS F EQUIPMENT	PER				
CHECK ALL CONTROLS A DAMPERS	ND				
REPLACE ALL FILTERS					



RELIGIOUS PROPERTY BUILDING REPAIR & RESTORATION A CORNERSTONE OF QUALITY SINCE 1960 P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBLEM

INTERIOR	MAJOR	MINOR	OK	OBSERVATION	DATE
CLEAN ALL RADIATOR ENCLOSURES AND AIR REGISTERS					
CLOSE ALL CRAWL SPACE OPENINGS USED FOR SUMMER VENTILATION					
REMOVE AND DISPOSE OF ALL DEBRIS					
PAINT ALL NEEDED AREAS					
CHECK ALL PANIC BARS AND LOCKING MECHANISMS					
REPAIR ALL BROKEN STAIR EDGES AS NEEDED					
LUBRICATE ALL NEEDED LOCKS AND HINGES					
LUBRICATE ALL NEEDED LOCKS					



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBL	EM				
ROOFING	MAJOR	MINOR	ОК	OBSERVATION	DATE
CLEAN ALL DRAINS EXTERIOR AND INTERIOR					
CLEAN ALL GUTTERS AND LEADERS					
CLEAN ALL VALLEYS FILL ALL PITCH POCKETS					
SECRE ALL FLASHING SYSTEMS					
SECURE ALL ANTENNA SYSTEMS COMPLETE ALL REPAIRS COMPLETE ROOF SURVEY					



P.O. BOX 620 DOVER, NEW JERSEY 07801 PHONE: (973) 442-9492 FAX: (973) 442-1552

MAINTENANCE INSPECTION CHECK LIST

BUILDING LOCATION

DATE

INSPECTOR

FALL PROBLEM EXTERIOR MAJOR MINOR OK OBSERVATION DATE **REMOVE, REPAIR AND STORE** SUMMER SCREENS **REMOVE AND STORE ALL EXTERIOR AWNINGS REPLACE ALL DEFECTIVE** WINDOW AND DOOR SEALANT CLEAN, REPAIR AND INSTALL STORM WINDOWS **REPLACE ALL NEEDED** WEATHERSTRIPPING **REPLACE ALL BROKEN GLASS**